



DATE : **OCTOBER 14, 2022**

TO : **ALL BIDDERS SIGNIFYING THEIR INTENT**

PROJECT : **Procurement of Three (3) Years Preventive Maintenance Services of Power Transformer and Low Voltage Switch Gear of CF-Bacolod under ITB No. CB22-08-003BACa-10**

I. INTRODUCTION:

This Bid Bulletin is issued to clarify, supplement, modify and/or revise the particular sections in the Bid and Contract Documents as stipulated in the Bidding Documents issued prior to this date. The Bidders shall take note of the following items carefully and consider them in the preparation of their bid proposals, as they shall form part of the CONTRACT DOCUMENTS.

II. INSTRUCTIONS:

This Bid Bulletin shall *form part of the submittals under the First (1st) Bid Envelope (Eligibility Documents and Technical Component of the Bid).*

III. CLARIFICATION/MODIFICATION IN THE BIDDING DOCUMENTS

SECTION VII. TECHNICAL SPECIFICATION		
Page	FROM	TO
29	TECHNICAL SPECIFICATION PREVENTIVE MAINTENANCE OF LOW VOLTAGE SWITCH GEAR SCOPE OF WORKS ➤ All works will be Performed by a Professional Electrical Engineer ➤ Free Monthly Check-up of all units	<u>TECHNICAL SPECIFICATION</u> <u>PREVENTIVE MAINTENANCE OF LOW VOLTAGE SWITCH GEAR</u> SCOPE OF WORKS ➤ All works will be Performed by a Professional Electrical Engineer or All works shall be supervised by a Professional Electrical Engineer ➤ Free Monthly Check-up of all units and shall submit a monthly report signed by a Professional Electrical Engineer

<p>30</p>	<p><u>PREVENTIVE MAINTENANCE OF POWER TRANSFORMER (3-333 KVA AND 3-100KVA)</u></p> <ul style="list-style-type: none"> ➤ Testing of Transformer units: <ul style="list-style-type: none"> I. Insulation resistance test II. Winding resistance test III. Turns ratio test Oil di-electric breakdown voltage test ➤ Free Monthly Check-up of all units ➤ All works will be Performed by a Professional Electrical Engineer <p><u>EMERGENCY CALLS</u></p> <ul style="list-style-type: none"> a. Problem identification b. Troubleshooting c. Minor Adjustments d. Recommendation/minor repair 	<p><u>PREVENTIVE MAINTENANCE OF POWER TRANSFORMER (3-333 KVA AND 3-100KVA)</u></p> <ul style="list-style-type: none"> ➤ Testing of Transformer units: <ul style="list-style-type: none"> I. Insulation resistance test II. Winding resistance test III. Turns ratio test Oil di-electric breakdown voltage test IV. Insulation Power Factor Test (IPF) ➤ Free Monthly Check-up of all units and shall submit a monthly report signed by a Professional Electrical Engineer ➤ All works will be Performed by a Professional Electrical Engineer or All works shall be supervised by a Professional Electrical Engineer <p><u>EMERGENCY CALLS</u></p> <ul style="list-style-type: none"> a. Problem identification b. Troubleshooting c. Minor Adjustments d. Recommendation/minor repair e. Free service unit on defective equipment during the repair.
-----------	---	---

Please be guided accordingly.

Please acknowledge receipt of this bid bulletin no. 01 and email it back to lillyann.jelbuena@pagcor.ph.

Thank you.

BEN M. POLIDO
 Chairperson
 BRANCH BIDS AND AWARDS COMMITTEE (BBAC)
 CASINO FILIPINO-BACOLOD

Received by:

 Signature over Printed Name

 Date